

Power transformers (In Service in EM-MPD Substations)					Nominal Voltages		Nameplate
Division	Substation	Sub	Name	Town	Pri. (kV)	Sec. (kV)	Capacity (MVA)
Central	Flo's Inn		T1	Presque Isle	138	69	100
Central	Flo's Inn		T2	Presque Isle	138	69	100
Central	Flo's Inn		T3	Presque Isle	69	12.5	10.5
Central	Ashland		T1	Ashland	69	34.5	12.5
Central	Ashland		T2	Ashland	69	34.5	12.5
Central	Ashland		T3	Ashland	69	12.5	2.5
Central	Easton		T1	Easton	69	12.5	3.4
Central	Fort Fairfield		T1	Fort Fairfield	69	12.5	7
Central	Loring	LR	T1	Limestone	69	12.5	9.4
Central	Mapleton		T1	Mapleton	69	12.5	6.3
Central	Mars Hill		T1	Mars Hill	69	12.5	9.4
Central	New Sweden	NS	T1	New Sweden	69	12.5	6.3
Central	North Presque Isle		T1	Presque Isle	69	12.5	12.5
Central	Otter Creek		T1	Caribou	69	12.5	7.5
Central	Pond		T1	Limestone	69	12.5	3.8
Central	Skyway		T1	Presque Isle	69	12.5	12.5
Central	Stete Street		T1	Presque Isle	69	12.5	12.5
Central	Washburn		T1	Washburn	69	12.5	3.8
Central	West Caribou		T1	Caribou	69	12.5	12.5
Central	Westfield		T1	Westfield	69	12.5	3.8
Island Falls	Mullen		T1	Houlton	69	44	16
Island Falls	Bridgewater		T1	Bridgewater	69	12.5	2.5
Island Falls	Island Falls		T1	Island Falls	44	12.5	3.1
Island Falls	Monticello		T1	Monticello	69	12.5	6.3
Island Falls	Oakfield	OA	T1	Oakfield	44	12.5	3.1
Island Falls	Patten		T1	Patten	44	12.5	2.5
Island Falls	Sherman		T1	Sherman	44	12.5	3.1
Fort Kent	Cross Lake		T1	Cross Lake TWP	69	12.5	3.1
Fort Kent	Fort Kent 12kV		T1	Fort Kent	69	12.5	9.4
Fort Kent	Fort Kent 35kV		T2	Fort Kent	69	34.5	9.4
Fort Kent	Frenchville		T1	Frenchville	69	12.5	6.3
Fort Kent	Grand Isle		T1	Grand Isle	69	12.5	2.5
Fort Kent	Madawaska		T1	Madawaska	69	12.5	9.4